

## Pot Water Quality Limits

<b>Required Test</b>	<b>Current Limit</b>	<b>Comments</b>
Enterococci	0/100ml	
E.coli	0/100ml	
Coliforms	0/100ml	
Hydrocarbons <sup>1</sup>	< 10ppb	
Chlorides <sup>1</sup>	< 250 mgCl/l	
TVC <sup>2</sup>	<100 cfu/ml @ 22°C	
TVC <sup>2</sup>	<10 cfu/ml @ 37°C	

1 & 2 No legislative requirements for testing.

1. Recommend testing on new builds during first pot water loading and on older vessels with hydrocarbon/sea water pipes passing through pot water tanks.
2. Recommend TVC trend is monitored.

Please return form to: [karl.fear@omsuk.co.uk](mailto:karl.fear@omsuk.co.uk)